

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 13-51-08295
Name of Facility: Hialeah Elem
Address: 550 E 8 Street
City, Zip: Hialeah 33010

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public School
Owner: M-DCSB Food and Nutrition
Person In Charge: Rosa Iglesias Phone: 305-888-6709

Inspection Information

Purpose: Routine
Inspection Date: 8/29/2016

Begin Time: 12:40 PM
End Time: 01:50 PM

Additional Information

CENSUS	604
FEMALES	292
MALES	312

As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.

Violation Markings

SCHOOL SANITATION	X 11. Cleanliness & Repair	22. Solid Waste
1. School Site	12. Toilet Facilities	VECTOR/VERMIN CONTROL
2. Playground Equipment	13. Separation of Sexes	X 23. Infestation/Control
3. Athletic Equipment	14. Fixture Ratio	24. Brush/Trash
BUILDINGS	15. Handwash Facilities	25. Water Collection/Drainage
4. Construction	16. Showers/Fixtures	SAFETY
X 5. Maintenance & Repair	17. Shower Water Temp.	26. First Aid Kit
X 6. Lighting/Foot-Candles	WATER SUPPLY	FOOD
7. Heating, Ventilation, A/C	18. Installed/Operated/Maintained	27. Food Insp. Rpt.
8. Natural Ventilation	X 19. Drinking Fountains	OTHER
9. Mechanical Ventilation	20. Approved Source	28.
SANITARY FACILITIES	LIQUID/SOLID WASTE	29.
X 10. Provided/Accessible	21. Sewage Disposal	

General Comments

No General Comments Available

Email Address(es): rbiglesias@dadeschools.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

<p>Violation #5. Maintenance & Repair Replace missing ceiling tiles in room 097 (work order MC 31257), in the K building (work order MC31862) Replace stained ceiling tiles in room 097 and all other applicable rooms throughout the facility Clean vent in bathroom located in the clinic, in bathroom of room 227, in female bathroom 010 to remove dust build up Replace burnt light bulbs in bathroom 212, in room 228, in room 205, in room 097 and all other applicable rooms throughout the facility (work in progress) Secure light cover in bathroom 100E located in the media center Cover electrical outlet on wall in the K building CODE REFERENCE: Maintenance & Repair 64E-13.004(3)(b)(c). Buildings shall be kept clean and in good repair, free from hazardous conditions, such as loose or broken floor tiles and boards; loose moldings; loose hanging fixtures, pipes, and electric wires; and broken plaster. Furnishings and equipment shall be kept clean and in good repair, free of missing parts and hazards such as sharp edges, splinters, and protruding or rusty nails.</p>
<p>Violation #6. Lighting/Foot-Candles Repair lights in bathrooms of rooms 213 and 094 (work in progress) CODE REFERENCE: Lighting/Foot-Candles 64E-13.004(4)(a-d). Illumination in all instructional spaces shall be designed to provide a minimum of forty (40) foot-candles glare free at normal task level. Fixtures shall be so located that there will be uniform (within ten (10) foot-candles) illumination suitable for the activities conducted therein. All required illumination shall be designed so that the failure of any single unit, such as the burning out of an electric bulb will not leave any occupied area or means of egress in darkness. Illumination of chalkboards and other visual aids shall be designed to eliminate glare and shadows.</p>
<p>Violation #10. Provided/Accessible Restore running water at handwashing sinks in restroom 214, and in the handicap stall of male restroom 039 CODE REFERENCE: Provided/Accessible 64E-13.004(6). Every school plant shall be provided with toilet and hand washing facilities for all occupants. These facilities shall be located for convenient student access and faculty supervision and kept clean and in good repair. Faculty and staff facilities shall be provided in separate rooms from student facilities.</p>
<p>Violation #11. Cleanliness & Repair Repair toilet paper dispenser in the first stall of the right side in female restroom 010 CODE REFERENCE: Cleanliness & Repair 64E-13.004(6)(a). Walls to a height of at least 4' feet toilet partitions and floor of all toilet rooms shall be finished with impervious materials. All plumbing fixtures shall conform to the provisions of the local plumbing code. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Deodorizers shall not be used in toilet rooms.</p>
<p>Violation #19. Drinking Fountains Repair drinking water fountains located across bathroom 214, across bathroom 208 CODE REFERENCE: Drinking Fountains 64E-13.004(7)(b). Drinking fountains of an approved, sanitary slant jet type shall be provided in the ratio specified in the local building code or Chapter 64E-10, F.A.C. In no case shall fountains be located in any toilet room.</p>
<p>Violation #23. Infestation/Control Eliminate the presence of ants in the K building. I was informed by the teachers that the ants are coming from the ceiling of the classroom CODE REFERENCE: Infestation/Control 64E-13.004(10). Effective measures shall be used to prevent harborage, propagation, or infestations of rodents and all insects.</p>

Inspection Conducted By: Naissa Julien (31113)
Work: (305) 623-3500 ex. 24222
Date: 8/29/2016

Inspector Signature:

Handwritten signature of Naissa Julien.

Client Signature:

Handwritten signature of the client.